



Ref. Certif. No.

SG PSB-BT-04191

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|---|
| Product | Batteries (Rechargeable Li-ion Battery System) |
| Name and address of the applicant | Shanghai PYTES Energy Co., Ltd. No. 3492 Jinqian Road Fengxian District 201406 Shanghai PEOPLE'S REPUBLIC OF CHINA |
| Name and address of the manufacturer | Shanghai PYTES Energy Co., Ltd. No. 3492 Jinqian Road, Fengxian District, 201406 Shanghai, PEOPLE'S REPUBLIC OF CHINA |
| Name and address of the factory | Shanghai PYTES Energy Co., Ltd. No. 3492 Jinqian Road, Fengxian District, 201406 Shanghai, PEOPLE'S REPUBLIC OF CHINA |
| Ratings and principal characteristics | See page 2 |
| Model/type Ref. | HV48100 BMU-5 HV48100 BMU-6 HV48100 BMU-7 HV48100 BMU-8 HV48100 BMU-9 HV48100 BMU-10 HV48100 BMU-11 HV48100 BMU-12 HV48100 BMU-13 HV48100 BMU-14 HV48100 BMU-15 |
| A sample of the product was tested and found to be in conformity with | IEC 62619:2022 |
| as shown in the Test Report Ref. No. which forms part of this certificate | 085-282360300-000 |

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 003364 0019 Rev. 00

Date, 2023-09-27

(Harry Zhang)



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Trademark / Brand (Image)



Parameters:

Nominal voltage: HV48100 BMU-5: 256Vd.c.
HV48100 BMU-6: 307.2Vd.c.
HV48100 BMU-7: 358.4Vd.c.
HV48100 BMU-8: 409.6Vd.c.
HV48100 BMU-9: 460.8Vd.c.
HV48100 BMU-10: 512Vd.c.
HV48100 BMU-11: 563.2Vd.c.
HV48100 BMU-12: 614.4Vd.c.
HV48100 BMU-13: 665.6Vd.c.
HV48100 BMU-14: 716.8Vd.c.
HV48100 BMU-15: 768Vd.c.

Rated capacity: 100Ah

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 003364 0019 Rev. 00

Date, 2023-09-27



(Harry Zhang)